

**CORRIGENDUM-7**

Last Date of Submission of Proposal: 13-05-2021, 02:00 PM, Opening of Pre-Qualification Bids on 13-05-2021, 04:00 PM

**Revised Request for Proposal – Extension of Odisha State Data Centre – OSDC 2.0**

**Selection of System Integrator for Design, Build, Installation, Commissioning, Integration, and Operations & Maintenance of Non-IT & IT Infrastructure for Extension of Odisha State Data Centre (OSDC 2.0).**

**Tender Enquiry No: OCAC-NEGP-INFRA-008-2018-20038**

Odisha Computer Application Centre (OCAC)

(Technical Directorate of E&IT Department, Govt. of Odisha)

S.N.	Page No.	Clause No.	Clause header	Clause details as in revised RFP/Corrigendum	Modification/ Remarks
1	121	5.22.3 (3)	Precision Air Conditioning System (Direct Expansion In-ROW)	Unit return air temperature : 28 Deg C /40%RH (Scalable to 37 Deg C)	"The return air temperature range (28 deg to 37 deg) is given considering various factors such as Rack variable load, variable ambient conditions and cold aisle set point temperature range. For ease of capacity calculation, bidder may consider 32+/-1 as return air temp at extreme conditions. However, the unit must work without performance deration on variable conditions."
2	127	5.22.5 (12)	Diesel Generators	All major performance component of DG sets like Engine, Alternator, Radiator, Battery etc should have the same make only for better coordination, maintenance & manageability.	RFP Clause No 5.22.5 Diesel Generators, Point No-12 (Page No-127) may be read as below:  "All major performance component of DG sets like Engine, Alternator, Radiator, etc. should be supplied by same OEM only for better coordination, maintenance & manageability."
3	141	5.22.9	Passive Networking	G. Requirement for CAT 6A LSZH U/UTP RJ45 Patch Cords-point 6 The cordage shall be UTP components that do not include internal or external shields, screened components or drain wires.	RFP Page No-141, Clause No-5.22.9 (Passive networking), Section-G (Requirement for CAT 6A LSZH U/UTP RJ45 Patch Cords-point 6) may be read as follows:  "The cordage shall be UTP / FTP or STP components that do not include internal or external shields, screened components or drain wires."
4	156	5.22.16	Dry Type Transformer	Rating/Sizing: 3 MVA dry type 33/.433	"The Bidder has to propose the suitable type/category of the Transformer as per the design & solution."
5	223	7.2 (6)	Core Router	The Router should support Separate data and control planes to provide greater flexibility and enable continual services. Router shall offer	RFP Clause No 7.2 Core Router, Point No-6 (Page No-223) may be read as below:  "The Router should support Separate data and control planes to provide greater flexibility and enable continual services. "

S.N.	Page No.	Clause No.	Clause header	Clause details as in revised RFP/Corrigendum	Modification/ Remarks
				with hardware redundant supervisor/management module	
6	239	7.10 (11)	Tape Library	a) OEM shall be in the leader's quadrant as per the latest Gartner's MQ report for General Purpose Disk Array OR MQ report for DCN. b) OEM must have India presence for last 5 years on both Sales and Support operation.	RFP Clause No 7.11 Tape Library, Point No-11 (Page No-239) may be read as below:  a) OEM must have India presence for last 5 years on both Sales and Support operation.
7	248	7.14 (41)	DDOS	OEM should be in the Leader's Circle DDOS Solution in as per the latest published Forrester Report	RFP Clause No 7.14 DDOS, Point No-41 (Page No-248) may be read as below: " OEM should be in the Leader's Circle DDOS Solution in as per the latest published Forrester Report/IDC Marketscape report ".
8	270	7.22 (23)	SDN Solution	The solution shall support Real-Time Overlay to Underlay Correlation or equivalent technology for overlay to underlay correlation	RFP Clause No 7.22 SDN Solution, Point No-23 (Page No-270) may be read as below: "The fabric / virtualization / orchestrator solution shall support Real-Time Overlay to Underlay Correlation or equivalent technology for overlay to underlay correlation".
9	270	7.22 (24)	SDN Solution	The solution shall support Historical Failures Root Cause and Impact Analysis.	RFP Clause No 7.22 SDN Solution, Point No-24 (Page No-270) may be read as below: " The solution shall support Historical Failures Root Cause or Impact Analysis".
10	270	7.22 (25)	SDN Solution	The solution shall support Real-Time Overlay Failures Root Cause Analysis: Configuration Problems SDN	RFP Clause No 7.22 SDN Solution, Point No-25 (Page No-270) may be read as below: " Clause Dropped".

S.N.	Page No.	Clause No.	Clause header	Clause details as in revised RFP/Corrigendum	Modification/ Remarks
				controller and SW-VTEP or HW-VTEP	
11	270	7.22 (26)	SDN Solution	The solution shall support Real-Time Overlay Failures Root Cause Analysis and Impact Analysis: Underlay Reachability Problems between SDN controller and SW-VTEP or HW-VTEP	RFP Clause No 7.22 SDN Solution, Point No-26 (Page No-270) may be read as below: "The solution shall support Real-Time Overlay Failures Root Cause Analysis or Impact Analysis: Underlay Reachability Problems between SDN controller/Virtualization and SW-VTEP or HW-VTEP".
12	272	7.23 (24)	Anti-APT Solution	Proposed ATP solution should integrate with FW, Endpoint Security and Server Security for intelligence sharing using security protocols.	RFP Clause No 7.23 Anti-APT Solution, Point No-24 (Page No-272) may be read as below: "Proposed ATP solution should integrate (if needed) with FW, Endpoint Security and Server Security for intelligence sharing using security protocols".
13	272	7.23 (35) and Corrigendum - 2 , S.No-63 , Page No.24	Anti-APT Solution	"Solution should be in the recommend list as per the latest published NSS report or equivalent report/ should have more than 99% detection rate as per ICSA certification".	RFP Clause No 7.23 Anti-APT Solution, Point No-35 (Page No-272) may be read as below: "Clause Dropped"
14	279	7.27 (11)	Multi-Function Printer (Print, Copy, Fax, Scan)	Scan Resolution: Up to 1200 x 1200 dpi	RFP Clause No 7.27 Multi-Function Printer (Print, Copy, Fax, Scan), Point No-11 (Page No-279) may be read as below: " Scan Resolution: Up to 600 x 600 dpi "
15	386-387	Annexure -A	(As-Is Inventory List of Current SDC)	Network Equipment	"Note: The Bidder shall not quote for the AMC price of ArcSight SIEM tool.".

S.N.	Page No.	Clause No.	Clause header	Clause details as in revised RFP/Corrigendum	Modification/ Remarks
16	391	Annexure -A	(As-Is Inventory List of Current SDC)	Storage and Back Up Devices Details.	“Storage and Back Up Devices Details: Page No. 391, Sl. No. 41. DELL SAN Storage - Serial Number- F0GYKG2 including enclosure serial numbers - F0L1LG2, F093LG2, 16G49R2 Page No. 391, Sl. No. 42. NAS - Serial Number- DFD1VG2”
17	394	Annexure -A	(As-Is Inventory List of Current SDC)	Current Desktop, Laptop & Printer Details.	“Current Desktop, Laptop & Printer Details: Page No.394, Sl.No. 11. Desktop (HP COMPAQ DX2480) - Serial Number- INA927038H”