CORRIGENDUM-II

RFP ENQ. No.- OCAC-NEGP-INFRA-0016-2022-24030, Dated – 22/02/2024, for selection of agency for supply, Installation and Commissioning of Uninterruptible Power infrastructure upgradation at SDC, OCAC

<u>Important</u>: The corrigendum is to be read, duly signed and submitted along with the RFP document published on the websites https://enivida.odisha.gov.in/, https://enivida.odisha.gov.in/ https://enivida.gov.in/ <a href="https://enivida.

SI. No	Page No.	Clause No	RFP Clause	Detail of as mentioned in section / clause	Modification/ Addendum/ Clarification
					Modification:
1.	13	6	Detail Scope of work	Supply, installation, integration, warranty support, of 2 nos 300 KVA monolithic UPS system.	Supply, installation, integration, warranty support, of 2 nos 300 KVA monolithic UPS system.
				Supply, installation, integration, warranty support, of 2V VRLA 310000 VAH battery in each bank, including racks, intercell and inter tier connectors, battery breakers, and UPS to battery cables.	Supply, installation, integration, warranty support, of 2V VRLA 310000 VAH battery in each bank, including racks, intercell and inter tier connectors, battery breakers, and UPS to battery cables.
				Careful removal of 2 nos 300 KVA UPS systems with battery banks from the power rooms and offer a buy back value for the same.	Careful removal of 2 nos 300 KVA UPS systems with battery banks from the power rooms and offer a buy back value for the same.
				Supply, laying and termination of required input cables from panel to UPS systems if required.	Supply, laying and termination of required input cables from panel to UPS systems if required.
				Bidder need work closely with OCAC team on installation of the systems as the Datacenter is live. Any disturbances on power, can cause irreparable damages on the Datacenter. Shut down will be provided to installation team with prior intimation.	Bidder need work closely with OCAC team on installation of the systems as the Datacenter is live. Any disturbances on power, can cause irreparable damages on the Datacenter.
				mumauon.	No shut down or downtime will be provided for installation of UPS.
					As critical load is concern, UPS replacement must be completed without power outage. Bidder should produce details procedure for on line change over for the replacement of complete sets of UPS System.
					Bidder has to plan accordingly for removal of existing UPS and installation of new UPS.

SI. No	Page No.	Clause No	RFP Clause	Detail of as mentioned in section / clause	Modification/ Addendum/ Clarification
					Modification:
2.	22	_	OEM Pre- Qualification	OEM should have been present in India with their service center from past 10 years. Products quoted must be the running product in any Govt/ PSU from minimum past 3 years from the date of submission of the bid. (Copy of the performance certificate must be attached with the Pre- Qualification bid).	OEM should have been present in India with their service center from past 10 years. Products quoted must be the running product in any Govt / PSU from minimum past 3 years from the date of submission of the bid. (Copy of the performance certificate must be attached with the Pre-Qualification bid).
				OEM's similar product (300KVA UPS system) must have been in successful operation in at least 10 locations out of which at least 1 must be in Datacenter environment in the state of Odisha	OEM's similar product (150KVA UPS system) must have been in successful operation in at least 5 locations out of which at least 1 must be in Datacenter/ IT environment in the state of Odisha
				Annual average UPS OEM's sales turnover should be minimum ₹500 cr for last 3 FY ending 31st march 2023.	Annual average UPS OEM's sales turnover should be minimum ₹500 Cr. for last 3 FY ending 31st march 2023

Note: Bid Submission and Opening Date & Time Extended as per below schedule
Bid Submission Date and Time: 21 March 2024 by 02:00 PM

Bid Opening Date and Time: 21 March 2024 at 04:00 PM

Sd/-General Manager (Admn).