

QUOTATION CALL NOTICE

Sealed quotations are invited from local authorised Dealers / Firms for providing batteries for UPS of Amaron QUANTA MAKE, 12V, 65 AH at OCAC Tower, Acharya Vihar, Bhubaneswar. Interested agencies /dealers may obtain the specification, terms and conditions for submitting quotation from Notice Board of this office on any working day between 10.00 A.M to 3:00 P.M. or can also download it from the official website www.ocac.in.

Sealed quotations must reach this office within 15 days from the publication of this notice. The envelope containing the tender quotation should be super scribed with "Quotation for UPS Battery" addressed to the Administrative Officer, OCAC.

Sl. No.	Description of work	Size	Qty	Rate	Amount
1.	Supply and installation of 12 V, 65 AH, Amaron Quanta make (Warranty for 3 year)	set	470		
2.	Buyback of 470 Nos. batteries of Amaron Quanta make	set	470		

Terms and conditions of supply and execution:

1. The work shall be completed within 07 days from the date of issue of work order.
2. IT & GST clearance certificates to be submitted.
3. The price is inclusive of FOR and installation & all taxes.
4. Warranty certificate to be provided by the party and if any break-down occurs during warranty party will be held responsible and to do the need-full according to the situation.
5. Replacement Warranty: Warranty shall be at least 3 years from the date of Installation and Commissioning of batteries in physically/ operationally good condition. battery serial No. are furnished in warranty certificate at the time of supply.
6. Batteries should be delivered in original packing and the name of manufacturer should be either embossed or painted on the battery. Stickers are not allowed.
7. Date of manufacturing: Within 3 months preceding the date of supply. The manufacturing month/ year shall be clearly embossed on the battery.
8. Test reports: Test reports of batteries from accredited labs for batteries should be enclosed.
9. Manufacturing facility certification: ISO 9001, ISO 14001, ISO45001:2018.
10. OEM'S certification of valid Test Report of Battery.
11. OEM Bids specific authorization for sales and service original copy to be attached.
12. Bidder must have sales and service office in Bhubaneswar, Odisha and on it's GST registration certificate
13. Bidder must be a dealer / distributor of Battery OEM for at least 7 years in Odisha. Bonafide certificate from OEM must be attached.
14. The dealer / distributor must provide at least one PO copy of Central Govt /State Govt / PSU within the last 5 years.
15. An undertaking is required stating that the company is not blacklisted by the government.

Specification:

Nominal voltage	12 Volts	
Rated capacity (C ₂₀ Hour rate at 27°C)	65 Ampere Hour	
Dimensions (+2mm)	Length	351 mm
	Width	167 mm
	Height	175 mm
Weight +1.0 Kgs (approx.)	20.0 Kgs	

Characteristics:

Capacity @80.6°F (27°C)	20 hour rate (3.25A) upto 10.5v	65.0 Ah
	10 hour rate (5.59A) upto 10.5v	55.90 Ah
	5 hour rate (10.29A) spot 10.2v	51.40 Ah
	1 hour rate (36.36A) upto 9.6v	36.30 Ah
	15 minute rate (101.1A) upto 9.6v	25.20 Ah
Internal resistance	Fully charged battery 80.6°F(27°C)	9.40 m
Capacity affected (Temperature at C ₂₀ hour rate)	104°F(40°C)	110%
	80.6°F(27°C)	100%
	32°F(0°C)	80%
	5F(-15°C)	60%
Self discharge 80.6°F (27°C)	Capacity after 3 month storage	90%
	Capacity after 6 month storage	80%
Terminal Type	M6 x 20 mm Bolted	
Short circuit current		1382 A

**Administrative Officer**

1. PA to M.D., OCAC for kind information of M.D., OCAC.
2. PA to G.M., OCAC for kind information of M.D., OCAC.
3. Chief General Manager(Finance), OCAC for kind information.
4. Notice Board for wide publicity.
5. Sri B. K. Mohanty, DPO to publish the notice in OCAC website